

LIGHTING EQUIPMENT SCHEDULE

FIXTURE A: MAIN SALES FLOOR AREA - VALUELIGHT - 1x4SB-4F54-347 VOLT BALLAST W/W SPECULAR REFLECTOR, AND C/W VAL-YHYTG-120 SUSPENSION KIT + LAMPS

FIXTURE P: EXTERIOR WALL PACKS - VALUELIGHT SM-727-H40-120 WALL PACK SWITCHED BY PHOTO-CEL

NOTE: ELECTRICAL CONTRACTOR SHALL REVIEW DIVISION 15 PLANS AND SPECIFICATIONS TO DETERMINE THE COMPLETE SCOPE OF WORK REQUIRED TO CONNECT ALL MECHANICAL COMPONENTS TO THE BUILDING ELECTRICAL SYSTEM.

DESIGN & INSTALL ALL MECHANICAL SYSTEMS TO THE FOLLOWING CODES AND STANDARDS.

- ALBERTA BUILDING CODE - 2006
- ALBERTA FIRE CODE - LATEST EDITION
- CANADIAN ELECTRICAL CODE - LATEST EDITION
- NATIONAL BUILDING CODE - LATEST EDITION
- NATIONAL FIRE CODE - LATEST EDITION
- NFPA-13 & ALL OTHER APPLICABLE NFPA SECTIONS
- CANADIAN PLUMBING CODE - LATEST EDITION
- NATURAL GAS INSTALLATION CODE CGA-B149
- SMACNA

FIELD REVIEW:

THE ENGINEERS HAVE BEEN RETAINED ONLY FOR PERIODIC SITE INSPECTIONS TO ENSURE GENERAL COMPLIANCE OF THE REVIEWED PORTIONS OF THE PROJECT TO THE CONTRACT DOCUMENTS.

SITE SAFETY:

THE ENGINEERS ASSUME NO RESPONSIBILITY FOR ON-SITE WORKER SAFETY FOR OTHER THAN THEIR OWN EMPLOYEES. THE OWNER AND/OR CONTRACTOR SHALL BEAR RESPONSIBILITY FOR SITE SAFETY AS PER THE OCCUPATIONAL HEALTH AND SAFETY ACT.

PLANS EXAMINATION:


DRAWINGS ARE NOT TO BE USED FOR CONSTRUCTION UNTIL REVIEWED AND APPROVED BY THE AUTHORITY HAVING JURISDICTION. THIS AUTHORITY, BASED ON APPLICABLE CODES, MAY REQUIRE REVISIONS AND/OR ADDITIONS AND THIS MAY RESULT IN EXTRA COSTS. THESE COSTS ARE UNFORESEEN AND THEREFORE, ARE THE RESPONSIBILITY OF THE OWNER AND/OR CONTRACTOR.

COPYRIGHTS:

ALL DRAWINGS, DESIGNS AND RELATED DOCUMENTS ARE THE PROPERTY OF THE ENGINEER, PROTECTED BY COPYRIGHT AND MUST BE RETURNED ON REQUEST. REPRODUCTION OF DRAWINGS AND DOCUMENTS IN PART OR IN WHOLE IS FORBIDDEN WITHOUT THE ENGINEER'S PERMISSION. DRAWINGS AND DOCUMENTS ARE TO BE USED ONLY FOR THE PURPOSE FOR WHICH THEY ARE ISSUED AND ARE NOT TO BE USED FOR CONSTRUCTION UNLESS SIGNED BY THE ENGINEER.

DRAWING REVIEW:

DRAWINGS MUST NOT BE SCALED. THE CONTRACTOR MUST CROSS-REFERENCE ALL ARCHITECTURAL, STRUCTURAL, FOUNDATION, ELECTRICAL AND MECHANICAL DRAWINGS AND VERIFY ALL DIMENSIONS, DRAWINGS AND SPECIFICATIONS ON SITE. ANY DISCREPANCIES MUST BE REPORTED TO THE ARCHITECT/ENGINEER PRIOR TO PROCEEDING WITH ANY PART OF THE WORK.



MAY 24, 2011


REVISIONS			
NO.	DESCRIPTION	DATE	CK
1	ISSUED FOR APPROVAL ONLY	APR 27 11	
2	FOR BUILDING PERMIT	JUN 22, 11	

R. Lamontagne, P. Eng.
 P.O. Box 2531
 Didsbury, Alberta, T0M 0W0
 Tel: (403) 703 6161
 E MAIL: ralamont@shaw.ca

PROJECT
 VALUE VALLAGE ADDITION 2011
 10127 - 34 AVENUE NW
 EDMONTON, AB
 T6E 6J8

TITLE
 FRONT POWER AND LIGHTING

SCALE AS SHOWN	DATE MAY 24, 2011	DRAWING NO. E2
DRAWN BY rl	CHECKED BY rw	REVISION: 2
JOB #: 1107	DWG:	PLOTTED:
		COPIED:



FRONT PARTIAL PLAN - POWER AND LIGHTING
 1/8"=1'-0"